Division Two Blow Off

Division Two Blow Off



Location	end_of_south_nason_road
Default State	Closed

ID:271

This is a blow off valve at the end of the Division Two distribution main. The valve is opened using the Large Valve Key.

FIXME: Should we be opening this valve periodic to flush the dead end and distribution main?

From:
https://yodelinwater.org/wiki/ - **Yodelin Water**

Permanent link:
https://yodelinwater.org/wiki/components:valves:blowoff:division_two_blowoff

Last update: **2026/09/04 20:38**