Maintenance

Annual

- Clean the top of the Reservoir
- Test the Alarm Light. Lift the Reservoir Level Sensor out of the tank, the alarm light should come on, and turn off when the sensor is returned.
- Walk the neighborhood and inspect all Cabin Shutoff Valves, Main Shutoff Valves, and Blowoff Valves valves. Listen for leaks, clear any vegetation that could impede access, ensure Cabin Shutoff Valve Markers are properly located and upright.
- Update Water Facilities Inventory Form by June 15th

Monthly

- Record the pump hours and reservoir level.
- Visually inspect the pump house for any damage or changes.
- Check the level of the ph Treatment Tank. Shine a bright light through the tank to see the level of the calcite. If it is low, schedule a service.

From:
https://yodelinwater.org/wiki/ - **Yodelin Water**

Permanent link:
https://yodelinwater.org/wiki/operations:maintenance

Last update: **2026/07/14 20:44**