

Maintenance

Annual

- Clean the top of the [Reservoir](#)
- Test the [Alarm Light](#). Lift the [Reservoir Level Sensor](#) out of the tank, the alarm light should come on, and turn off when the sensor is returned.
- Walk the neighborhood and inspect all [Cabin Shutoff Valves](#), [Main Shutoff Valves](#), and [Blowoff Valves](#) valves. Listen for leaks, clear any vegetation that could impede access, ensure [Cabin Shutoff Valve Markers](#) are properly located and upright.
- Update [Water Facilities Inventory Form](#) by June 15th

Monthly

- Record the pump hours and reservoir level.
- Visually inspect the pump house for any damage or changes.

From:
<https://yodelinwater.org/wiki/> - **Yodelin Water**

Permanent link:
<https://yodelinwater.org/wiki/operations:maintenance?rev=1784076191>

Last update: **2026/07/14 20:43**

