

2025 Sanitary Survey

Significant deficiencies and significant findings identified during this sanitary survey:

- Samples for [Testing](#) are done from the pump house and not from locations in our distribution system
 - Larry was able to get approval from DOH to continue sampling from the pump house because 1) the operator would need to traverse avalanche terrain to sample from homes 2) many homes are not regularly occupied and orchestrating unattended water operator access would be difficult and risky.
- [Yodelin WS_29316_SS2025_Updated WFI_2025-09-11.pdf](#)
- [Yodelin_29316_SS2025 Cover Letter_2025-10-01.pdf](#)
- [Yodelin_29316_SS2025 Evaluation Checklist.pdf](#)
- [Yodelin_29316_SS2025 Invoice_2025-10-01.pdf](#)
- [Yodelin_29316_SS2025 Photos.pdf](#)
- [Yodelin_29316_SS2025 Schematic.pdf](#)

From:

<https://yodelinwater.org/wiki/> - **Yodelin Water**

Permanent link:

https://yodelinwater.org/wiki/sanitary_surveys:2025_survey

Last update: **2026/07/03 23:07**

