

2025 Sanitary Survey

Significant deficiencies and significant findings identified during this sanitary survey:

- Samples for [Testing](#) are done from the pump house and not from locations in our distribution system
 - Larry was able to get approval from DOH to continue sampling from the pump house because 1) the operator would need to traverse avalanche terrain to sample from homes 2) many homes are not regularly occupied and orchestrating unattended water operator access would be difficult and risky.

From:

<https://yodelinwater.org/wiki/> - **Yodelin Water**

Permanent link:

https://yodelinwater.org/wiki/sanitary_surveys:2025_survey?rev=1783131491

Last update: **2026/07/03 22:18**

